Product data sheet

Specifications

Communicating opening voltage release MX, MasterPact NT drawout, 277VAC

33796

Main

Range	MasterPacT
Range Of Product	MasterPact NT
Device Short Name	MX com
Product Or Component Type	Voltage release
Device Application	Control
Voltage Release Type	Opening coil Instantaneous voltage release
Control Type	Communicating
[Uc] Control Circuit Voltage	277 V AC 50/60 Hz
Circuit Breaker Mounting Mode	Drawout
Range Compatibility	Masterpact MasterPact NT

Complementary

Operating Threshold	0.7...1.1 x Un opening
Response Time	50 ms +/- 10 %
Supply Holding Power	4.5 VA

Packing Units

Unit Type Of Package 1	PCE
Number Of Units In Package 1	1
Package 1 Height	9.0 cm
Package 1 Width	6.0 cm
Package 1 Length	8.0 cm
Package 1 Weight	1.169 kg

Contractual warranty

Warranty	18 months

Sustainability

Green Premium™ label is Schneider Electric's commitment to delivering products with best-in-class environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO_2 products.

Guide to assessing product sustainability is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium ›

Guide to assess a product's sustainability ›

Transparency   RoHS/REACh

Well-being performance

✓ Mercury Free

✓ Rohs Exemption Information   Yes

Certifications & Standards

Reach Regulation   REACh Declaration

Eu Rohs Directive   Compliant with Exemptions

China Rohs Regulation   China RoHS declaration

Product out of China RoHS scope. Substance declaration for your information

Environmental Disclosure   Product Environmental Profile

Circularity Profile   End of Life Information

California Proposition 65   WARNING: This product can expose you to chemicals including: DINP, which is known to the State of California to cause cancer, and DIDP, which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov