

# Contactor, TeSys K, 3P, AC-3/ AC-3e,440V 12A, aux. 1NC, 100V AC coil, screw clamp terminals

LC1K1201K7

### Main

Range	TeSys
Product Or Component Type	Contactor
Device Short Name	LC1K
Device Application	Control
Contactor Application	Motor control Resistive load
Complementary	
Utilisation Category	AC-3 AC-3e AC-1 AC-4
Poles Description	3P
Power Pole Contact Composition	3 NO
[Ue] Rated Operational Voltage	Power circuit: <= 690 V AC <= 400 Hz Signalling circuit: <= 690 V AC <= 400 Hz
[le] Rated Operational Current	12 A (at <60 °C) at <= 440 V AC AC-3 for power circuit 12 A (at <60 °C) at <= 440 V AC AC-3e for power circuit 20 A (at <60 °C) at <= 690 V AC AC-1 for power circuit
Control Circuit Type	AC at 50/60 Hz
[Uc] Control Circuit Voltage	100 V AC 50/60 Hz
Motor Power Kw	3 kW at 220230 V AC 50/60 Hz AC-3 5.5 kW at 380415 V AC 50/60 Hz AC-3 5.5 kW at 440 V AC 50/60 Hz AC-3 4 kW at 690 V AC 50/60 Hz AC-3 3 kW at 220230 V AC 50/60 Hz AC-3e 5.5 kW at 380415 V AC 50/60 Hz AC-3e 5.5 kW at 380415 V AC 50/60 Hz AC-3e 4 kW at 690 V AC 50/60 Hz AC-3e 3 kW at 220230 V AC 50/60 Hz AC-3e 5.5 kW at 380415 V AC 50/60 Hz AC-4 5.5 kW at 380415 V AC 50/60 Hz AC-4 5.5 kW at 440 V AC 50/60 Hz AC-4 4 kW at 690 V AC 50/60 Hz AC-4
Auxiliary Contact Composition	1 NC
[Uimp] Rated Impulse Withstand Voltage	8 kV
Overvoltage Category	III
[Ith] Conventional Free Air Thermal Current	20 A (at 60 °C) for power circuit 10 A (at 50 °C) for signalling circuit

144 A AC for power circuit conforming to IEC 60947 110 A AC for signalling circuit conforming to IEC 60947

Irms Rated Making Capacity

Rated Breaking Capacity	110 A at 440 V conforming to IEC 60947 80 A at 500 V conforming to IEC 60947
	70 A at 660690 V conforming to IEC 60947
[Icw] Rated Short-Time Withstand	115 A 50 °C - 1 s for power circuit
Current	105 A 50 °C - 5 s for power circuit
	100 A 50 °C - 10 s for power circuit
	75 A 50 °C - 30 s for power circuit 55 A 50 °C - 1 min for power circuit
	50 A 50 °C - 3 min for power circuit
	25 A 50 °C - >= 15 min for power circuit
	80 A - 1 s for signalling circuit
	90 A - 500 ms for signalling circuit 110 A - 100 ms for signalling circuit
	- 107. 100 iii oo
Associated Fuse Rating	25 A gG at <= 440 V for power circuit
	25 A aM for power circuit  10 A gG for signalling circuit conforming to IEC 60947
	10 A gG for signalling circuit conforming to VDE 0660
Average Impedance	3 mOhm - Ith 20 A 50 Hz for power circuit
Insulation Resistance	> 10 MOhm for signalling circuit
Inrush Power In Va	30 VA (at 20 °C)
Hold-In Power Consumption In Va	4.5 VA (at 20 °C)
Heat Dissipation	1.3 W
Control Circuit Voltage Limits	Operational: 0.81.15 Uc (at <50 °C)
Control Circuit Voltage Limits	Drop-out: >= 0.20 Uc (at <50 °C)
Connections - Terminals	Screw clamp terminals 1 cable(s) 1.54 mm²solid
	Screw clamp terminals 1 cable(s) 0.754 mm²flexible without cable end
	Screw clamp terminals 1 cable(s) 0.342.5 mm²flexible with cable end
	Screw clamp terminals 2 cable(s) 1.54 mm²solid Screw clamp terminals 2 cable(s) 0.754 mm²flexible without cable end
	Screw clamp terminals 2 cable(s) 0.341.5 mm²flexible with cable end
Maximum Operating Rate	3600 cyc/h
Auxiliary Contacts Type	type instantaneous 1 NC
	type instantaneous 1 NC <= 400 Hz
Auxiliary Contacts Type	
Auxiliary Contacts Type Signalling Circuit Frequency	<= 400 Hz
Auxiliary Contacts Type Signalling Circuit Frequency Minimum Switching Current	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit  1020 ms coil de-energisation and NO opening
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit  1020 ms coil de-energisation and NO opening
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit  1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing  B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit  1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing  B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time	<= 400 Hz  5 mA for signalling circuit  17 V for signalling circuit  1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing  B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance	<= 400 Hz 5 mA for signalling circuit 17 V for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3 eat Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn f
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn f
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn f
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3e at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Z axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Vibrations contactor closed: 4 Gn, 5300 Hz conforming to IEC 60068-2-6
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability  Mechanical Robustness	<= 400 Hz 5 mA for signalling circuit 1020 ms coil de-energisation and NO opening 1020 ms coil energisation and NO closing B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 0.5 mm 10 Mcycles 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 1.3 Mcycles 12 A AC-3 at Ue <= 440 V 0.3 Mcycles 20 A AC-1 at Ue <= 690 V 0.02 Mcycles 72 A AC-4 at Ue <= 440 V Shocks contactor closed, on X axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Z axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Vibrations contactor opened: 2 Gn, 5300 Hz conforming to IEC 60068-2-6 Vibrations contactor opened: 2 Gn, 5300 Hz conforming to IEC 60068-2-6
Auxiliary Contacts Type  Signalling Circuit Frequency  Minimum Switching Current  Minimum Switching Voltage  Operating Time  Safety Reliability Level  Non Overlap Distance  Mechanical Durability  Electrical Durability  Mechanical Robustness	<ul> <li>&lt;= 400 Hz</li> <li>5 mA for signalling circuit</li> <li>1020 ms coil de-energisation and NO opening</li> <li>1020 ms coil energisation and NO closing</li> <li>B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1</li> <li>B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1</li> <li>0.5 mm</li> <li>10 Mcycles</li> <li>1.3 Mcycles 12 A AC-3 at Ue &lt;= 440 V</li> <li>1.3 Mcycles 12 A AC-3e at Ue &lt;= 440 V</li> <li>0.3 Mcycles 20 A AC-1 at Ue &lt;= 690 V</li> <li>0.02 Mcycles 72 A AC-4 at Ue &lt;= 440 V</li> <li>Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27 Shocks contactor opened; 2 Gn, 5300 Hz conforming to IEC 60068-2-6 Vibrations contactor opened: 2 Gn, 5300 Hz conforming to IEC 60068-2-6</li> </ul>

### **Environment**

Standards	EN/IEC 60947-4-1 GB/T 14048.4 UL 60947-4-1 CSA C22.2 No 60947-4-1 JIS C8201-4-1	
Product Certifications	CB Scheme CCC UL CSA EAC CE	
Protective Treatment	TC conforming to IEC 60068 TC conforming to DIN 50016	
Operating Altitude	2000 m without derating	
Flame Retardance	V1 conforming to UL 94 Requirement 2 conforming to NF F 16-101 Requirement 2 conforming to NF F 16-102	

# **Packing Units**

Unit Type Of Package 1	PCE
Number Of Units In Package 1	1
Package 1 Height	6.6 cm
Package 1 Width	4.8 cm
Package 1 Length	6.2 cm
Package 1 Weight	182.0 g

## **Contractual warranty**

Warranty 18 months

### **Sustainability**

**Green Premium<sup>TM</sup> label** is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO<sub>2</sub> products.

**Guide to assessing product sustainability** is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >





Transparency RoHS/REACh

## Well-being performance

<b>⊘</b>	Reach Free Of Svhc	
<b>⊘</b>	Toxic Heavy Metal Free	
<b>⊘</b>	Mercury Free	
<b>⊘</b>	Rohs Exemption Information	Yes

#### **Certifications & Standards**

Reach Regulation	REACh Declaration
Eu Rohs Directive	Compliant EU RoHS Declaration
China Rohs Regulation	China RoHS declaration  Pro-active China RoHS declaration (out of China RoHS legal scope)
Environmental Disclosure	Product Environmental Profile
Circularity Profile	End of Life Information