

Additional SDE fault trip indication contact, MasterPact MTZ2/3, 1 changeover contact, standard 6A/240VAC, spare part

LV847915SP

Main

Range	MasterPact	
Device Short Name	SDE	
Product Or Component Type	Auxiliary contact	
Device Application	Control	
Range Compatibility	Masterpact MasterPact MTZ2 circuit breaker Masterpact MasterPact MTZ3 circuit breaker	

Complementary

Auxiliary Contacts Type	Standard	
Signal Contacts Composition	1 NO/NC 6 A	
[Ith] Conventional Free Air Thermal Current		
Breaking Capacity	6 A AC-12 240/380 V AC 50/60 Hz 2 A AC-12 480 V AC 50/60 Hz 3 A DC-12 24/48 V DC 0.3 A DC-12 125 V DC 0.15 A DC-12 250 V DC	
Minimum Load	100 mA at 24 V	
Provided Equipment	1 instruction sheet	
Offer Type	Spare part	

Packing Units

Unit Type Of Package 1	PCE
Number Of Units In Package 1	1
Package 1 Height	4.0 cm
Package 1 Width	5.5 cm
Package 1 Length	10.0 cm
Package 1 Weight	102.0 g
Unit Type Of Package 2	S03
Number Of Units In Package 2	10
Package 2 Height	30.0 cm
Package 2 Width	30.0 cm
Package 2 Length	40.0 cm
Package 2 Weight	1.365 kg

Sustainability

Green PremiumTM label is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO₂ products.

Guide to assessing product sustainability is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >

Well-being performance

	Reach Free Of Svhc	
	Toxic Heavy Metal Free	
	Mercury Free	
	Rohs Exemption Information	Yes
Rea	ch Regulation	REACh Declaration
Eu F	Rohs Directive	Compliant
		EU RoHS Declaration
Chir	na Rohs Regulation	China RoHS declaration
		Pro-active China RoHS declaration (out of China RoHS legal scope)
Calif	fornia Proposition 65	WARNING: This product can expose you to chemicals including: DINP, which is known to the State of California to cause cancer, and DIDP, which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov