

Certificate of Compliance

Certificate Number 120901-E63335C
Report Reference E63335, August 10, 2001
Issue Date 2001 September 12

Page 1 of 2



Issued to: **Merlin Gerin, DBA Schneider Electric S A**
Av Des Jeux Olympics, 38050
Grenoble Cedex 9 France

*This is to certify that
representative samples of*


Molded Case Circuit Breakers
Powerpact P with suffix G, J, K or L rated 800 A & 1200 A

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: UL 489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

Additional Information: See Addendum For Ratings Information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Gail Zielen*
Gail Zielen, Sr. Engineering Associate
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*
Antonio Romanacce, Manager
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 120901-E63335C

Report Reference E63335, August 10, 2001

Issue Date 2001 September 12

Page 2 of 2



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

These breakers are rated 800 A through 1200 A and have a maximum voltage rating of 600 Vac.

INTERRUPTING RATINGS:

Circuit Breaker Type	S.C. Interrupting Rating (kA, rms, sym)			
	PG	PJ	PK	PL
240Vac, 1ph. - 3ph	65	65	65	65
240Vac	65	100	65	125
480Vac, 1ph - 3ph, 3 pole only	35	65	50	100
480Vac	35	65	50	100
600Vac	18	25	50	-

Issued by: *Gail Zielen*
Gail Zielen, Sr. Engineering Associate
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*
Antonio Romanacce, Manager
Underwriters Laboratories Inc.