



Certificate of Compliance

Certificate: 2304490

Master Contract: 240515

Project: 2304490

Date Issued: June 21, 2010

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaitre

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Key-operated limit switches, Cat. Nos. XCS-LE and XCS-LF, followed by a six-digit number, followed by 2 or 3 followed by 21 or 24, may be followed by a two digit number; rated:

- Supply/Electromagnet voltage: 24 Vac/dc or 120 Vac or 230Vac
- Output: Pilot duty, C300, R300
- Enclosure Type: 4/4X or 12, for model Cat. No. XCS-LF (metallic housing); 4X (indoor use only) or 12, for model Cat. No. XCS-LE (polymeric housing)

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures