

Declaration of Conformity

Customer Reference :

Product: Prisma G cubicles

We, Schneider Electric, guarantee Prisma G has been tested in CESI lab for a seismic withstand. The enclosures have been tested according to the standards IEC60068-3-3 & 2-57. Reports number B5014477 & B6010967, mentioned the following acceleration capacity :



We can declare that during these seismic tests, the electrical continuity was maintained, and after the enclosure kept its IPxxb and mechanical functionalities.

This result is based on a typical assemblies of Prisma G wall-mounted & floor-standing enclosures without additional accessories, and the equipment has been assembly according to the Prisma catalogs, mounting instructions.