



# 中国国家强制性产品认证证书

证书编号：2011010305503533

委托人名称、地址

Schneider Electric Asia Pte Ltd  
50 Kallang Avenue, Singapore 339505

生产者（制造商）名称、地址

PT. Schneider Electric Manufacturing Batam  
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka  
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

生产企业名称、地址

PT. Schneider Electric Manufacturing Batam  
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka  
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

安全限位开关

XCSPA,XCSTA: Ui:500V;Uimp:6kV;lth: 10A; AC-15: Ue/le: AC240V/3A ; DC-13: Ue/le :  
DC250V/0.27A; IP67

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2019年05月30日 有效期至：2021年09月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2011年10月13日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：

陆楠



## 中国质量认证中心





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.:** 2011010305503533

## **NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric Asia Pte Ltd  
50 Kallang Avenue, Singapore 339505

## **NAME AND ADDRESS OF THE MANUFACTURER**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning  
Kec. Sungai Beduk – Batam, Indonesia

## **NAME AND ADDRESS OF THE FACTORY**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning  
Kec. Sungai Beduk – Batam, Indonesia

## **PRODUCT NAME, MODEL AND SPECIFICATION**

安全限位开关

XCSPA,XCSTA: Ui:500V;Uimp:6kV;lth: 10A; AC-15 : Ue/le : AC240V / 3A ; DC-13 :  
Ue/le : DC250V / 0.27A; IP67

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** May.30,2019

**Valid until:** Sep.28,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Oct.13,2011

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



## **CHINA QUALITY CERTIFICATION CENTRE**





# 中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2011010305503533

纸 号: 2280167

型号解释:

XCSP I	A II	5 III	9 IV	1 V
I -	产品基本型号 XCS-P - 1 个电缆入口 XCS-T - 2 个电缆入口			
II -	操作头 A - 插入型			
III -	触头模块 对 XCSP: 5 - 1NO + 1NC 先断后通慢动型 7 - 2NC 慢动型  对 XCST: 7 - 2NC + 1NO 先断后通慢动型			
IV -	操纵杆的位置和形式 9-对于杠杆型操作头: 折弯杠杆左位 对于插入型操作头: 无闭锁			
V -	入口 1 - 11 号欧洲电缆密封管螺纹孔 2 - M16 ISO 电缆密封管螺纹孔 3 - 1/2 in. NPT 螺纹孔 或提供 1/2 in. NPT 联结头			

注: 此附录与证书同时使用时有效。



主 任: 陆梅



## 中国质量认证中心